

**RESOLUTION 89-21**

**RESOLUTION APPROVING EMERGENCY REPAIR TO CLAYTON'S  
SEWER COLLECTION SYSTEM**

**WHEREAS**, Gregory Sawyer, Principle Public Works Manager has submitted  
Certification of Request for Emergency purchase; and

**WHEREAS**, it has been determined that said purchase and repair is an  
emergency condition; and

**WHEREAS**, Gregory Sawyer, Principle Public Works Manager, has issued  
said request (attached hereto) indicating the reasons said emergency exists; and

**WHEREAS**, Gregory Sawyer, Principle Public Works Manager, had obtained  
quotes from Garrison Enterprise and Pioneer Pipe, to repair said emergency dated  
April 6, 2021; and

**WHEREAS**, the governing body is in agreement that said emergency contract  
must be awarded without public bidding pursuant to N.J.S.A. 40A:11-6.

**NOW, THEREFORE, BE IT RESOLVED** by the Mayor and Council of the  
Borough of Clayton, County of Gloucester, and State of New Jersey as follows:

1. That the governing body does hereby authorize the contract  
with Pioneer Pipe for the repair of said emergency in the  
amount of \$23,000.00.

**ADOPTED** at a meeting of the Mayor and Council of the Borough of Clayton,  
in the County of Gloucester, State of New Jersey, held on April 22, 2021.


BOROUGH OF CLAYTON



---

THOMAS BIANCO, Mayor

Attest:

  
\_\_\_\_\_  
CHRISTINE NEWCOMB  
Borough Clerk

**CERTIFICATION**

I, Christine Newcomb, Clerk of the Borough of Clayton, do hereby certify that the foregoing Resolution was presented and duly adopted by the Borough Council at a regular meeting of the Borough of Clayton Council, held on April 22, 2021.

\_\_\_\_\_  
CHRISTINE NEWCOMB, Borough Clerk

## **Certification of Request for Emergency Purchases**

The Department Head certifies as follows:

1. On April 6 2021 The Borough Water & Sewer Department was called to 253 N Dennis to investigate a sewer problem. An emergency condition was discovered in the Borough of Clayton's Sewer Collection System. The sewer lateral at 253 N Dennis was broken or collapsed. Attempts by our Public Works personnel to dig up and repair were unsuccessful. The break was over 8' deep. Groundwater conditions along with the depth, combined to make a seriously unsafe condition. It was determined that our personnel and equipment could not keep up with the water or perform the needed repairs.

I contacted two different underground Utility Contractors in the South Jersey area. Garrison Enterprise was not available for the emergency service but Pioneer Pipe was.

2. This condition constitutes an emergency affecting the public health, safety and/or welfare of the public.

3. Description of the conditions and how it affects the public, health, safety and/or welfare:

The sewer is broken and pulling mud into the main potentially causing more sewer backups in the area and a severe Public Health hazard. Roadway is open and collapsing and extremely dangerous to the Public.


4. This emergency occurred on: April 6, 2021.

5. It is necessary to invoke NJSA 40 A:11-6 in order to obtain the immediate delivery of the materials, supplies or the performance of the service(s) described in the attached purchase order. The estimated cost of furnishing the materials, supplies or services is \$23,000

6. It is requested that a purchase order be issued without public advertisement for bids, pursuant to the above cited statute.

7. I certify that the forgoing statements made by me are true. I am aware that if any of the foregoing statements are willfully false, I am subject to punishment.

  
\_\_\_\_\_  
Department Head Signature

  
\_\_\_\_\_  
Mayor or Department Chairperson Signature

**For Purchasing Authority Only:**

8. If approval is granted, record the purchase order(s) issued pursuant to the emergency \_\_\_\_\_

9. The maximum amount that may be expended under this emergency is  
\$ \_\_\_\_\_

Emergency Purchase Approved By:

\_\_\_\_\_  
Administrator